GOVERNMENT OF TAMIL NADU

DIRECTORATE OF PUBLIC HEALTH AND PREVENTIVE MEDICINE

பொது சுகாதாரம் மற்றும் நோய்த் தடுப்பு மருந்துத்துறை

SELF DECLARED SANITATION CERTIFICATE

(Issued under G.O.(Ms)No. 276 of Health and Family Welfare (AB2) Department dated 23.09.2024 on the basis of affidavit by the applicant)

Certificate Number : TN00126TUP46874 **Issued Date : 07-08-2026**

Organization Type : Educational Institutions **Expiry Date : 06-08-2027**

Name of the Organization : SENTHOOR VELAN ACADEMY

Address : SF NO 1121/3A2,1121/3A3&1121/3B,DOOR NO 40 VELLAVAVIPUTHUR VILLAGE,MALLIPATTI PIRIVU,METTUVALASU POST,POLARAI,KOLATHUPALAYAM VIA,DHARAPURAM TALUK,TIRUPPUR DISTRICT-638661

I, **B PARAMESHWARI** owner/manager of the **SENTHOOR VELAN ACADEMY** functioning as **Educational Institutions** located at **Moolanur** in **Tiruppur** district hereby declare that

- This Self-Declared Sanitation certificate is valid from **07-08-2026** to **06-08-2027** and will be renewed every year prior to the expiry of the current certificate with updated information.
- Our premises can accommodate **85** people/pupils and has **8** urinals and **6** toilets which is proportionate to the number of users as per government norms.
- **2** Sanitation workers are deployed to clean the entire premises including Toilets, Common Area Spaces, etc., at regular intervals and proper record is maintained.
- The waste generated on our premises is properly processed and disposed of as per Solid Waste management Rules, 2016.
- There is no potential mosquito breeding area on the premises.
- The premises have adequate drinking water fountains on each floor of the premises.
- The self-declared certificate is displayed prominently on the premises along with the protocol

The Government reserves the right to inspect at any point of time and cause for rectification or cancel or suspend the certificate and take legal action if any conditions are violated.

B Parameswari

CORRESPONDENT
SENTHOOR VELAN ACADEMY
Mallipatti Pirivu, Mettuvalasu (Po) Polarai
Kolathupalayam(Via), Dharapuram(Tk),
Tiruppur District - 638 661.

Signature of the Owner/Manager

(அ) TN00126TUP46874 என்ற தனிப்பட்ட சான்றிதழ் எண்ணை https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/ ல் உள்ளீடு செய்து சரிபார்க்கவும்.

(அல்லது)

(ஆ) கைப்பேசியில் பார்கொடு படிப்பான் மூலம் இணையதளத்தில் சரிபார்க்கவும்.

Genuineness of the certificate can be verified by.

(a)Keying in the unique certificate number TN00126TUP46874 in the URL https://www.tnesevai.tn.gov.in/edistrict/CheckStatus/Certificate/

(or)

(b)Reading the 2D barcode with mobile barcode reader and verify through online.

TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 471 & 472, Bharathiyar Complex, Avinashi Road,
Tiruppur – 641602.

Phone: 0421 - 2245201 E-mail: labtpr@gmail.com

TC - 15221

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Sample / Lab No:	TR/2026/244-1	Report Issue Date :	04.08.2026
Invoice Details:	3320/Dt.29.07.2026/ Amt.Rs.1,652/-		
ULR No:	TC152212600000232F		

Client Name & Address Contact No / Email.ID	:	M/s.Senthoor Velan Academy, Mallipatti pirivu, Mettuvalasu (Po), Polarai, Kolathupalayam (Via), Dharapuram (Tk), Tiruppur District – 638 661.
Sample Name	:	Water- Drinking
Sample Description	:	Bore well water
Sample Code No	:	244-1
Sample Submitted by	:	Customer- Thiru.T.Vasanthakumar
Location & Date	:	RO water at M/s. Senthoor Velan Academy & 29.07.2026
Quantity of sample Received	:	2 Litre
Sample Container	:	Plastic – Good condition.
Sample Condition on Receipt	:	Good
Sample Received On	:	29.07.2026
Test Commenced on	:	29.07.2026
Test Completed on	:	30.07.2026
Environmental Condition	:	23.0°C-27.0°C

S.No	Parameters	Test Method	Unit	Result	Specification as per IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	pH @ 25° C	IS 3025 Part 11-2022	--	7.24	6.5-8.5	6.5-8.5
2	Total Alkalinity as $CaCO_3$	IS 3025 Part 23-2023	mg/L	28	200	600
3	Total Hardness as CaCO3	IS 3025 Part 21-2009 (RA:2023)	mg/L	34	200	600
4	Chloride as Cl	IS 3025-Part 32-1988 (RA:2019)	mg/L	10	250	1000
5	Sulphate as SO4	IS 3025–Part 24- Sec 1-2022	mg/L	< 5	200	400
6	Nitrate as NO_3	IS 3025–Part 34- Sec 1-2023	mg/L	12	45	45
7	Fluoride as F	IS 3025–Part 60- Sec 1-2023	mg/L	< 0.2	1.0	1.5

Remarks : The Tested sample conformed IS:10500:2012 Drinking water specification (Acceptable Limit / Permissible Limit) with respect to above tested Parameters.

Reviewed & Authorised Signatory
B.George - Junior Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

..... End of the Report.....

TAMILNADU WATER SUPPLY AND DRAINAGE BOARD

DISTRICT WATER TESTING LABORATORY

No. 471 & 472, Bharathiyar Complex, Avinashi Road,
Tiruppur – 641602.

Phone: 0421 - 2245201 E-mail: labtpr@gmail.com

TEST REPORT

Doc.No: DWTL/FORM/7.8/01

Sample / Lab No:	TR/2026/244-2	Report Issue Date :	04.08.2026
Invoice Details:	3320/Dt.29.07.2026/ Amt.Rs.1,652/-		

					IS 10500 : 2012	
					Acceptable Limit	Permissible Limit in the absence of alternate source
1	Appearance	Physical observation	--	Clear	-	-
2	Colour	IS 3025-Part 4	Hazen	< 2	5	25
3	Odour	IS 3025-Part 5	--	Agreeable	Agreeable	Agreeable
4	Turbidity	IS 3025-Part 10	NTU	< 0.5	1	5
5	Total Dissolved Solids	IS 3025-Part 16	mg/L	76	500	2000
6	Conductivity	IS 3025-Part 14	µS/cm	108	-	-
7	P – Alkalinity as $CaCO_3$	IS 3025–Part 23-1983	mg/L	Nil	-	-
8	Calcium as Ca	IS 3025–Part 40	mg/L	8	75	200
9	Magnesium as Mg	IS 3025–Part 46	mg/L	3	30	100
10	Iron as Fe	IS 3025–Part 53	mg/L	< 0.1	0.3	1
11	Manganese as Mn	IS 3025–Part 59	mg/L	< 0.05	0.1	0.3
12	Ammonia as NH_3	IS 3025–Part 34	mg/L	< 0.5	0.5	0.5
13	Nitrite as NO_2	IS 3025–Part 34	mg/L	< 0.01	-	-
14	Total Phosphate as PO_4	IS 3025–Part 31	mg/L	< 0.1	-	-
15	Residual Chlorine	IS 3025–Part 26	mg/L	< 0.2	0.2	1.0
16	Fecal Coliform	IS 1622	CFU/ 100ml	0 / 100ml	0 / 100ml	0/100ml

Remarks : The Tested sample conformed IS:10500:2012 Drinking water specification (Acceptable Limit / Permissible Limit) with respect to above tested Parameters.

Reviewed & Authorised Signatory
B.George - Junior Engineer

Note:

1. The test results relate only to the items tested.
2. The test report shall not be reproduced anywhere except in full and in the same format without the permission of the laboratory.
3. Unless informed by customer, the test items will not be retained for more than 15 days from the date of issue of the test report.
4. The result applied to the sample as received basis.

..... End of the Report.....

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Dated:11.08.2026

It is certified that an inspection team headed by **A.ARULANANDAM, BLOCK HEALTH SUPERVISOR (I/C) from GOVT PRIMARY HEALTH CENTRE, MULANUR** inspected the **SENTHOOR VELAN ACADEMY S.F.NO : 1121/3A2,1121/3A3 & 1121/3B ,VELLAVAVIPUDUR VILLAGE, MALLIPATTI PIRIVU, METTUVALASU(POST) POLARAI, KOLATHUPALAYAM(VIA), DHARAPURAM (TK), TIRUPPUR (DT)** on **07.08.2026** and on the basis of Water Test Report (Attached) bearing no **DWTL/FORM/7.8/01** dated **04.08.2026** of **DISTRICT WATER TESTING LABORATORY TIRUPPUR** certified that the **SENTHOOR VELAN ACADEMY** has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt. This certificate is valid till **ONE YEAR**

11.08.26

BLOCK HEALTH SUPERVISOR (I/C),

GOVT PRIMARY HEALTH CENTRE,

MULANUR

TO

SENTHOOR VELAN ACADEMY,

MALLIPATTI PIRIVU,

KARUR MAIN ROAD,

MULANUR, DHARAPURAM (TK),

TIRUPPUR (DT)- 638 661